



**DEEP BELLED SCHEDULE 40 AND 80 UL/CSA
AND NON-UL/CSA PVC CONDUIT**

In an effort meet customer demand we have changed all of PVC extrusion line belling equipment over to provide a deeper bell on all of UL Schedule 40, Schedule 80 and Non-UL Schedule 40 conduit. Over the next couple of weeks you will begin to see this product enter your marketplace as we deplete inventory of shorter belled product with that of the new deeper belled conduit.

Below please find a chart that provides our new bell depths by conduit trade size.

**Schedule 40 & 80 (All UL/CSA and Non-UL/CSA, as well as all Canadian
product)**

Trade Size	Carlon Part Number	Nominal Bell (Socket) Depth
1/2" (0.500")	49005 (UL Sch. 40), 49405 (UL Sch. 80), 59610 (Non-UL Sch. 40)	1.375"
3/4" (0.750")	49007 (UL Sch. 40), 49407 (UL Sch. 80)	1.500"
1" (1.000")	49008 (UL Sch. 40), 49408 (UL Sch. 80)	1.750"
1-1/4" (1.250")	49009 (UL Sch. 40), 49409 (UL Sch. 80)	1.875"
1-1/2" (1.500")	49010 (UL Sch. 40), 49410 (UL Sch. 80)	2.750"
2" (2.000")	49011 (UL Sch. 40), 49411 (UL Sch. 80), 59611 (Non-UL Sch. 40)	3.250"
2-1/2" (2.500")	49012 (UL Sch. 40), 49412 (UL Sch. 80), 59612 (Non-UL Sch. 40)	3.250"
3" (3.000")	49013 (UL Sch. 40), 49413 (UL Sch. 80), 59613 (Non-UL Sch. 40)	3.875"
3-1/2" (3.500")	49014 (UL Sch. 40)	3.875"
4" (4.000")	49015 (UL Sch. 40), 49415 (UL Sch. 80), 59615 (Non-UL Sch. 40)	4.625"
5" (5.000")	49016 (UL Sch. 40), 49416 (UL Sch. 80), 59616 (Non-UL Sch. 40)	5.625"
6" (6.000")	49017 (UL Sch. 40), 49417 (UL Sch. 80), 59617 (Non-UL Sch. 40)	6.375"

25701 Science Park Drive
Cleveland, Ohio 44122
216-464-3400
1-800-3CARLON (322-7566)
www.carlon.com